

Customer: \_\_\_\_\_ P.O. \_\_\_\_\_

UPDATED ON MAY 09, 2016 / NTS3400\_20160509

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

LEVEL PROBE ORDER FORM

Email: \_\_\_\_\_

REQUEST FOR QUOTATION

NTS 3400	NTS 3400A	NTS 3450	NTS 3400T						
<i>Single Float Probe</i>	<i>Multi-Float Probe</i>	<i>Leak Detector Probe</i>	<i>Probe c/w Test Rod</i>						
<p>MEASURE FROM TOP TO BOTTOM</p> <p>(inches)</p> <p>FL1</p> <p>FL2</p> <p>FL3</p> <p>FL4</p> <p>FL5</p> <p>OR</p>	<p>(inches)</p> <p>FL1</p> <p>FL2</p> <p>FL3</p> <p>FL4</p> <p>FL5</p> <p>OR</p>	<p>ADJ.</p> <p>TANK BOTTOM</p>	<p>TEST ROD</p> <p>(inches)</p> <p>FL1</p> <p>FL2</p> <p>FL3</p> <p>FL4</p>						
<p><b>MODEL:</b></p> <p>NTS 3400 - [ ] / [ ]"</p> <p>NTS 3400A - [ ] / [ ]"</p> <p style="margin-left: 100px;">LOW FLOAT (FL5)</p> <p style="margin-left: 100px;">LEVEL(S)</p> <p><b>TANK DEPTH</b></p> <p>[ ]</p> <p><b>TOTAL LEVEL'S</b></p> <p>[ ]</p>	<p><b>MODEL:</b></p> <p>NTS 3450 - 1 / [ ]"</p> <p style="margin-left: 100px;">LOW FLOAT</p> <p style="margin-left: 100px;">LEAK LEVEL</p> <p><b>TANK DEPTH</b></p> <p>[ ]</p>	<p><b>MODEL:</b></p> <p>NTS 3400T - [ ] / [ ]"</p> <p style="margin-left: 100px;">LOW FLOAT (FL4)</p> <p style="margin-left: 100px;">LEVEL(S)</p> <p><b>TANK DEPTH</b></p> <p>[ ]</p> <p><b>TOTAL LEVEL'S</b></p> <p>[ ]</p>							
<p><b>MATERIAL:</b> <input type="checkbox"/> BRASS    <b>BUSHING:</b> <input type="checkbox"/> 1.5"    <input type="checkbox"/> 2"</p>		<p><b>MATERIAL:</b> <input type="checkbox"/> STAINLESS STEEL    <b>BUSHING:</b> 2" ONLY</p>							
<b>FLOAT LAYOUT</b> (INCHES)	<b>SWITCH FUNCTION</b>	<b>CONTACT STATUS</b> NO LIQUID IN TANK, ALL FLOATS DOWN	<b>TYPE OF JUNCTION BOX</b> TYPE 4 WATER PROOF						
FL1 _____"	_____	OPEN <input type="checkbox"/> CLOSE <input type="checkbox"/>	<div style="display: flex; justify-content: space-around;"> <div style="text-align: center;"> <p>LB</p> </div> <div style="text-align: center;"> <p>RECT</p> </div> </div>						
FL2 _____"	_____	OPEN <input type="checkbox"/> CLOSE <input type="checkbox"/>	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:50%;">PROBE TEST VOLTAGE</th> <th style="width:50%;">TEST TIME</th> </tr> <tr> <td>1000 + 2V <input type="checkbox"/></td> <td>60s <input type="checkbox"/></td> </tr> <tr> <td>1200 + 2V <input type="checkbox"/></td> <td>s <input type="checkbox"/></td> </tr> </table>	PROBE TEST VOLTAGE	TEST TIME	1000 + 2V <input type="checkbox"/>	60s <input type="checkbox"/>	1200 + 2V <input type="checkbox"/>	s <input type="checkbox"/>
PROBE TEST VOLTAGE	TEST TIME								
1000 + 2V <input type="checkbox"/>	60s <input type="checkbox"/>								
1200 + 2V <input type="checkbox"/>	s <input type="checkbox"/>								
FL3 _____"	_____	OPEN <input type="checkbox"/> CLOSE <input type="checkbox"/>							
FL4 _____"	_____	OPEN <input type="checkbox"/> CLOSE <input type="checkbox"/>							
FL5 _____"	_____	OPEN <input type="checkbox"/> CLOSE <input type="checkbox"/>							

**NOTE:** 1) INTERTEK CERTIFICATE NUMBER: 4009854. THESE UNITS ARE TO BE SUPPLIED FROM A CLASS 2 ELV (LESS THAN 30V) CIRCUIT. SWITCH CONTACT RATED: 500 mA 24Vac / Vdc, MAX.  
 2) PROBES SHOW NO LIQUID IN TANK. 3) CONSULT NWTCT FOR 1.5" BUSHING STAINLESS STEEL PROBE.



**NORTHWEST TECH-CON SYSTEMS LTD.**

#104 - 7450 Lowland Drive, Burnaby, BC V5J 5A4, CANADA Tel: (604) 439-1046 Fax: (604) 439-1079

E-mail: info@nwtc.ca / Web Site: www.nwtc.ca