



MOTOR AND PUMP ALARM

HISL

High Motor Temperature and Pump Seal Failure Annunciator

Model(s): HISL - I operates Single Pump
 HISL - II operated Dual Pump

Northwest Tech-Con System's HISL system is designed to detect and monitor motor high temperature and pump seal failures. It is for use with all makes of pumps equipped with normal closed high motor temperature and an open leak detector probe (in pump chambers) which senses resistance between itself and the ground



MOTOR FAILURE ALARM

MFA

Northwest Tech-Con System's MFA monitors running motor failure on all makes of motors where motor failure is caused by a wiring burn out, tripped circuit breaker or an overload. A visual and audible alarm operates simultaneously to alert when a motor failure occurs.

